3.3 CMD_PD

Hardware manual

www.pinetek-networks.com




Table of Contents

3.3 CMD_PD 5

3.3 CMD_PD

This command exchanges the process data with the connected device. Process data is not validated in length or content.

Command:

Octet #	Usage
0	Command ID = 0x03
1	Port index 0x00 or 0x01
2	Length Out
3	Length In
4..	Data Out

The ***Length Out*** field command is length for the output process data. The structure and length of the output data can be found in the SDCI device's documentation. The ***Length In*** field needs to be set according to the device's documentation. If the length fields are not correctly set, this may lead to invalid data or loss of communication.

Return Success:

Octet #	Usage
0	Command ID = 0x03
1	Port index 0x00 or 0x01
2	Length Out (as given in the command)
3	Length In (as given in the command)
4..	Data In